



Possible Mineral Extraction Works in Ardleigh Area - Site A80

© Affinity Water Limited. © Crown Copyright and database rights 2024 Ordnance Survey 100025261.
 Plans are the property of Affinity Water Limited and may not be reproduced or distributed in any form (or any part) without the written permission of Affinity Water Limited.
 Plans are continuously being updated, so out of date plans should be destroyed and not relied upon. The position of apparatus shown on this plan is provided for guidance only and should not be relied upon as being precise.
 Therefore the Company accepts no responsibility in the event of inaccuracy. Service pipes are not necessarily shown on this plan. Cover is normally 115mm for mains and 750mm for communication pipes but this may vary.
 The actual position of apparatus must be determined on site by making hand dug trial holes. The Company requires a minimum of two working days notice of the intention to excavate trial holes.
 Except where prior written permission has been obtained, it is an offence under Section 174 of the Water Industry Act 1991 to operate or interfere with any valves, hydrants or other apparatus vested in Affinity Water.



	Distribution Main		Cable
	Asbestos Distribution Main		Hydrant
	Abandoned Main		Fitting
	Asbestos Abandoned Main		Easement
	Communication Pipe ***		Company Boundary
	Supply Pipe ***		
	Other / Private Pipe ***		
	Adit / Tunnel		

*** position of Communication, Supply or Other pipes shown may be inaccurate or out-dated and should not be relied upon.