

- Access for Fire Service purposes must be considered in accordance with the Essex Act 1987 – Section 13, with new roads or surfaces compliant with the table below to withstand the standard 18 tonne fire appliances used by Essex County Fire and Rescue Service.

	Min. Width of Road between Kerbs	Min. Width of Gateways	Min. Height Clearance	Min. Carrying Capacity	Min. Turning Circle (Kerb to Kerb)	Min. Turning Circle between Walls	Sweep Circle
Pumping Appliance	3.7m	3.1m	3.7m	18 tonnes	17.8m	19.0m	19.0m
High Reach	3.7m	3.1m	4.0m	26 tonnes	17,8m	20.0m	